

HIGHER F950 Series Turbine Flow transducer

user's manual



Content

1. Digital paddlewheel meters	P01
2. Range	P02
3. External dimension	P03
4. KF510 lectotype	P03
5. Installation requirements	P04
6.Terminal Description	
1.)Terminal Description	P05
2.)Electric current output	P06
3.)Pulse, frequency output	P06
4.Function of communication	P07
7.Operations	
1.)Panel construction and key definition	P07
2.)Function instructions	P07
3.)menu construction	P08
4.)detail parameter instructions	P09
5.)Detail instructions	
5.1 Unit of flow	P10
5.2 Instantaneous flow Resolution	P11
5.3 Unit of total	P12
5.4 Cumulative total flow resolution	P13
5.5 Damping time (S)	P14
5.6 New Password	P15
5.7 Scale flow (m3/h)	P16
5.8 Small flow termination%(low %)	P17
5.9 Frequency upper limit Hz	P18
5.10 Liter/pulse(L/P)	P19
5.11 Cumulate Clear	P20
5.12 Preset total positive	P21

1. Digital paddlewheel meters

F950 series is as a speed flow metering,used to measure the full closure of pipeline and continuous flow of volume liquid.it is good for low viscosity liquids that can with high accuracy of instant and totalizer flow.

Features:

High accuracy digital paddlewheel technology

Rate and total flow display

Easy to operations and read,eight large digital LCD display

Install quickly on existing pipe

No pressure drop

Corrosion resistant PVDF sensor

Minimal maintenance required

Long-life lithium battery

Stopped-flow instructions

Diversification installation

Totalizer :can be reset and the
permanent preservation

User set security password

Paddlewheel flow sensor

Item	paddlewheel flow sensor
Velocity range	0.3~6m/s
Diameter	DN10-DN50 (with PVDF triplet) DN50-250(insert type)
Wetted material	Sensor:PVDF Impeller:PVDF Shaft lever:ceramics
Seal ring	Viton,EPDM
Working temperature	PVDF: -20~ +140°C
Working pressure	1.0MPa , 0.8MPa


Technical parameter

Item	Flow Convertor
Model	F950
Full scale accuracy	±1% , ±1.5%(full scale)
Repeatability	±0.5%
Temperature	-20~ +65°C
External dimension	100x100mm
Installation method	Panel mount、compact type
Power supply	DC24V, battery power supply, AC220V(optional)
Output signal	4~20mA, Passive pulse
Communication	RS485
Alarm	Upper limit,lower limit,totalizer
Protection class	IP65
Consumption	2W

2. Range

Technical parameter

DN (mm)	Range (m³/h)	Male	Press (MPa)	temp. (°C)	A mm	B mm
10	0.1~1.8	G3/8"	1.0	≤80°C	152	121
15	0.2~4	G1/2"			152	130
20	0.3~6	G3/4"			158	142
25	0.5~12	G1"	0.8		158	141
40	1.5~24	G1½"			168	175
50	2~40	G2"			184	175



Insert type Specifications:


DN(mm)	Range (m ³ /h)	C	N-ØA	Press (MPa)	temp. (°C)
50	3-30	125	4-Ø18	0.8	≤80°C
65	5-50	145	4-Ø18		
80	8-80	160	8-Ø18		
100	10-100	180	8-Ø18		
125	15-150	210	8-Ø18		
150	35-350	240	8-Ø22		
200	50-500	295	8-Ø22		
250	50-800	350	12-Ø22		

Application


- Water treatment systems
- Process treatment/ distribution
- Irrigation system
- Filtration system
- Swimming pool and hot spring
- Groundwater packing
- Counter-infiltration
- Process flow monitor
- Ultra-pure water delivery
- Desalination and recycle
- Process cooling water



3. External dimension





4. F950 lectotype



5. installation requirements


Minimum straight pipe length requirements

The digital paddlewheel meters' accuracy is affected by disturbances such as pumps, elbows, tees, valves, etc. in the flow stream, install the meter in a straight run of pipe as far as possible from any disturbances. the distance required for accuracy will depend on the type of disturbance.





Mounting location

The digital paddlewheel meters is designed to withstand outdoor conditions. a cool, dry location, where the unit can be easily serviced is recommended. the meter can be mounted on horizontal or vertical runs of pipe. mounting at the vertical (twelve o'clock) position on horizontal pipe is recommended. mounting anywhere around the diameter of vertical pipe is acceptable, however, the pipe must be completely full of water at all times. back pressure is essential on downward flows. see the minimum straight length of pipe requirement chart above. the meter can accurately measure flow from either direction.



45° acceptable


6. Terminal Description



1.)Terminal Description


Items	Label	Function Instructions	Remarks
1	4-20mA +	4-20mA Output positive terminal	1, Load resistance:750Q (with link) 2, Hart Communications external 24VDC power supply Active Output Mode
2	4-20mA -	4-20mA Output negative terminal	
3	0-2KHz+	Frequency/pulse output positive terminal	The output amplitude of 24V load current <=50mA
4	0-2KHz-	Frequency/pulse output negative terminal	
5	RS485date+	RS485 Communication positivetterminal	RS485 communication function (n just for transmitter has this function)
6	RS485date -	RS485 Communication negativetterminal	
7	Vo+	Hall parts supply	When the signal sensing element is a coil,connect signal + and signal -(hop cap connect AMP and ON) when signal sensing element is Hall Parts,hop cap connect AMP and OFF
8	SIN+	signal +	
9	SIN-	signal -	
10	(12-24V) +	24VDC Power, positive terminal	Power range: 12 VDC -24VDC
11	(12-24V) -	24VDC Power, negative terminal	
12	BAT+	battery supply+	When power is battery,we suggest pull out the hop cap of SW2 for extend battery service life.
13	BAT-	battery supply-	

2.) Electric current output



The converter current output electrical isolation has been achieved. Output to take an active approach. Current output mode 4-20mA, 20mA current output value from the corresponding traffic parameter item "scale flow of value" is determined (reference to factory nameplate on the instrument measuring range a value). The maximum current output load resistance of 750Q, the load resistance includes the cables used to connect the resistance. Current output cable is recommended RWP2x16/015 PVC insulated sheathed cable shield. 2.

3.) Pulse, frequency output




The Transmitter frequency, pulse output has been achieved electrical isolation, the output for the active mode (see above chart). Transmitter frequency, pulse output with transistor output mode. Maximum pulse output frequency 5KHZ, the output pulse amplitude of 24V. Active mode the maximum load current 50mA, passive mode the maximum load current 0.2A. As the frequency and pulse output terminals are shared, it is not to choice two output modes. Users can set the parameter "frequency output" to select the work. Frequency output upper limit corresponding to the measured flow value by the parameter item "scale flow value" decision (reference instruments to measure the scope of a factory nameplate values). Pulse output equivalent by the parameter 'pulse equivalent L / P "decision.

4.) Function of communication

Transmitter communication with RS485, MODBUSASC, MODBUSRTU communications capabilities (requires a user specified when ordering). Available through the "485 output communication protocol" parameter is set to specify. Instrument Communication Interface specific technical note on "protocol."

7.Operations

1.) Panel construction and key definition



2.) Function instructions

set parameters confirmation and set key of exit sub-menu (◀ key)

enter sub-menu and cancel set key(▶ key)

set item "DOWN" and data variables "degression" key(▼ key)

set item "MOVE" and data variables "increase"key (▲ key)

Instructions:

Instrument Display Interface

1. The first line shows an instantaneous flow rate, flow rate display units can be in the 'flow unit' function key to choose;
2. The second line shows the cumulative total amount and cumulative units;
- 3 . The third line shows the percentage of traffic

3.) menu construction

Mode of Measuree press 	Configuration Menu press. 	Parameter item Press 	Secondary Parameter item
	1. BASIC	1.1 PV Units	
		1.2 PV Decimal	
		1.3 Total Units	
		1.4 Total Decimal	
		1.5 Damping(s) (0.1~99.9)	
	2. SYSTEM	2.1 New Password	
		2.2 Language	
		2.2 Signal	1. Qmax(m3/h) 2. Low Cutoff%
		2.3 Pulse Output	1. Freq Direct 2. Freq Max(Hz) 3. Liter/Pulse 4. Pulse Width(ms) 5. Pulse Level
		2.4 RS485 Output	1. RS485 Protocol 2. Baudrate 3. Data Bit 4. Parity 5. Stop Bit 6. Dev Address
		2.5 Total Set	1. Clear Total 2. FWD preset(m3)
		2.6 Load Settings	
	3. CALIBRATION	3.1 4mA Trim	
		3.2 20mA Trim	
	4. TEST	4.1 Loop Test	
		4.2 Pulse Test	
Mode of Measuree Press	Configuration Menu press 	Parameter item Press 	Secondary Parameter item Press 







4.) detail parameter instructions

parameter item	parameter setting range	instructions
flow unit	L/S, L/m, L/h, m3/S, m3/m, m3/h, G/S, G/m, G/h	S=second,M=minute, H=hour,L=liter, M3=cubic meter,G=gallon
totalizer unit	L, m3,G	
flow display resolution	1, 2, 3	set the instantaneous flow of decimal places displayed
totalizer display resolution	1, 2, 3	set the totalizer flow of decimal places displayed
language	chinese, english	
scale flow	0.0001-999999999	unit: m3/h
termination of small flow	0.0-9.9	this parameter can move small flow display,the percentage for the full range
upper frequency limit	100.0-5000.0Hz	maximum frequency output,it's effectual when pulse equivalent is ZERO
pulse equivalent	larger than system's minimum is ok	one pulse on behalf of how many liters
pulse width	0.0-1000.0ms	do not need under normal condition
pulse level	low effective ,high effective	clear total accumulation
clear accumulation	No, Yes	
preset positive accumulation		If replace instrument,can input previous totalizer flow,continue to accumulation
4mA calibration	3.000-5.000	calibrate output signal without flow.
20mA calibration	19.000-21.000	calibrate output signal of full range

5). detail instructions







1.) Unit of flow

Adjust instant flow's unit, the setting rang L/S, L/min, L/h, m3/S, m3/min, m3/h, G/S, G/min, G/h.

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  into configuration menu	
2	Press "  into Basic menu	
3	Press "  into PV Units	
4	Press "  " or "  "set the Unit of flow	
5	Press "  "quit setup menu ,LCD show confirm menu	
6	Press "  "to confirm the change, Press "  "to give up modify	
7	Press "  "two times back to measurement, also you can continue other operation	







2.)Instantaneous flow Resolution

Adjust the instantaneous flow of small points indicate the medium, set the range of 1-3

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu	
2	Press "  " into Basic menu Click "  " to choice PV decimal	
3	Click "  " into " PV decimal menu	
4	Press "  " or "  "set the instantaneous flow Resolution	
5	Press "  "quit setup menu ,LCD show confirm menu	
6	Press "  "to confirm the change, Press "  "to give up modify	
7	Press "  "two times back to mesurement, also you can continue other operation	

3.) Unit of total

Adjust Total unit, setting range L,m3,gal

Steps	Operation instructions	Interface show
1	In the measurement mode, press "▶" into configuration menu	
2	Press "▶" into Basic menu Click "▼" to choice Total Unitsl	
3	Click "▶" into "Total Units menu	
4	Presses "▼" or "▲" " set the Unit of total	
5	Press "◀" quit setup menu ,LCD show confirm menu	
6	Press "◀" to confirm the change, Press "▶" to give up modify	
7	Press"◀"two times back to mesurement, also you can continue other operation	

4.)Cumulative total flow resolution

Adjusted cumulative flow dots show the median, set the range of 1-3 decimal places

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  into configuration menu	→ Basic → System → Calibration → Test →
2	Press "  into Basic menu Click "  to choice Total Decimal	PV Units PV Decimal Total Units ↓→Total Decimal
3	Click "  into " Total Decimal menu	Total Decimal 3 3
4	Prees "  " or "  "set the Cumulative total flow resolution	Total Decimal 3 2
5	Press "  "quit setup menu , LCD show confirm menu	Total Decimal 3 ←ENT ESC → 2
6	Press "  "to confirm the change, Press "  "to give up modify	PV Units PV Decimal Total Units ↓→Total Decimal
7	Press "  "two times back to mesurement, also you can continue other operatio n	







5.) Damping time (S)

Damping time on the meter display and output. Set range 0.1-99.9S (unit is "seconds").
Set as follows:

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu	→ Basic → System → Calibration → Test →
2	Press "  " into Basic menu Click "  " to choice Damping(S)	↑ PV Decimal Total Units Total Decimal → Damping(S)
3	Click "  " into " Damping(S) menu	Damping(S) 02.0 Max: 99.9 Min: 0.2 02.0
4	Press "  " or "  " and "  " set the Damping time	Damping(S) 02.0 Max: 99.9 Min: 0.2 03.0
5	Press "  " quit setup menu , LCD show confirm menu	Damping(S) 02.0 ← ENT ESC → 03.0
6	Press "  " to confirm the change , Press "  " to give up modify	↑ PV Decimal Total Units Total Decimal → Damping(S)
7	Press "  " two times back to measurement, also you can continue other operation ⁿ	

6.)New Password

System constituent's initial password:0200

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu,Click "  " to choice "System" item	
2	press the key of  ,show password interface,enter password,press the key of  enter into system constituent menu	
3	Click "  " into "New Password" menu	
4	Prees "  " or "  "and "  "set the New Password	
5	Press "  "quit setup menu , LCD show confirm menu	
6	Press "  "to confirm the change, Press "  "to give up modify	
7	Press "  "two times back to mesurement, also you can continue other operation	

7.)Scale flow (m3/h)

Meter-scale flow (QMAX) range depending on the caliber meter . Scale flow units: m3/h.

Steps	Operation instructions	Interface show
1	In the measurement mode, press “  ” into configuration menu, Click “  ” to choice “System” item	Basic → → System → Calibration → Test →
2	press the key of  , show password interface, enter password, press the key of  enter into system constituent menu	→ New Password Language Signal ↓ Pulse Output
3	Press “  ” to choice “Signal” item	New Password Language → Signal ↓ Pulse Output
4	Press “  ” into “Signal” menu	→ Qmax(m3/h) Low Cutoff%
5	Press “  ” into “Qmax(m3/h)” menu, Press “  ” or “  ” and “  ” set the Scale flow	Qmax(m3/h) Max: 99999999 100.0 Min: 0.000100 120.0
6	Press “  ” quit setup menu , LCD show confirm menu	Qmax(m3/h) 100.0 ← ENT ESC → 120.0
7	Press “  ” to confirm the change, Press “  ” to give up modify	Qmax(m3/h) Low Cutoff%
8	Press “  ” three times back to mesurement, also you can continue other operation	

8.) Small flow termination%(low %)

The parameters on the display and output are valid. When the traffic signal to terminate below the low flow rate (unit%) of the settings to set the value of the The signal will be removed, display and output to zero.

The termination of the small percentage is relative to the scale in terms of flow rate settings. Set As follows

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu, Click "  " to choice "System" item	Basic → → System → Calibration → Test →
2	press the key of  ,show password interface,enter password,press the key of  enter into system constituent menu	→ New Password Language Signal ↓ Pulse Output
3	Press "  " to choice "Signal" item	New Password Language → Signal ↓ Pulse Output
4	Press "  " into "Signal" menu Press "  " to choice "Low Cutoff" item	Qmax(m3/h) → Low Cutoff%
5	Press "  " into "Low Cutoff%" menu, Press "  " or "  " and "  "set the Small flow	Low Cutoff% Max: 9.9 1.0 Min: 0.0 1.0
6	Press "  "quit setup menu , LCD show confirm menu	Low Cutoff% 1.0 ← ENT ESC → 2.0
7	Press "  "to confirm the change, Press "  "to give up modify	Qmax(m3/h Low Cutoff%
8	Press "  "three times back to measurement, also you can continue other operation	

9.) Frequency upper limit Hz (output frequency range of the instrument 100-5000Hz)



When the Liter/ pulse = 0.0, the case "frequency cap Hz" setting determines the frequency of the output

When the Liter/pulse >0.0, the setting of L/P determines the frequency output

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu, Click "  " to choice "System" item	Basic → → System → Calibration → Test →
2	press the key of  , show password interface, enter password, press the key of  enter into system constituent menu	→ New Password Language Signal ↓ Pulse Output
3	Press "  " to choice "Pulse Output" item	New Password Language Signal ↓→ Pulse Output
4	Press "  " into "Pulse Output" menu, Press "  " to choice "Freq Max(Hz)" item	Freq Direct → Freq Max(Hz) Liter/Pulse ↓ PulseWidth(ms)
5	Press "  " into "Freq Max(Hz)" menu, Press "  " or "  " and "  " set the Frequency upper limit	Freq Max(Hz) 4000.0 Max: 5000.0 Min: 100.0 5000.0
6	Press "  " quit setup menu, LCD show confirm menu	Freq Max(Hz) 4000.0 ← ENT ESC → 5000.0
7	Press "  " to confirm the change, Press "  " to give up modify	Freq Direct → Freq Max(Hz) Liter/Pulse ↓ PulseWidth(ms)
8	Press "  " three times back to measurement, also you can continue other operation	






10.) Liter/pulse(L/P)

Scale corresponding to the current flow of output frequency








$$\text{Output Frq(Hz)} = \frac{\text{Current Flow(m3/h)} / 3.6}{\text{Liter/pulse(L/P)}} = \frac{\text{Current Flow(L/s)}}{\text{Liter/pulse(L/P)}}$$






Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu, Click "  " to choice "System" item	Basic → System Calibration Test
2	press the key of  , show password interface, enter password, press the key of  , enter into system constituent menu	→ New Password Language Signal ↓ Pulse Output
3	Press "  " to choice "Pulse Output" item	New Password Language Signal ↓→ Pulse Output
4	Press "  " into "Pulse Output" menu, Press "  " to choice "Liter/Pulse" item	Freq Direct Freq Max(Hz) → Liter/Pulse ↓ PulseWidth(ms)
5	Press "  " into "Liter/Pulse" menu, Press "  " or "  " and "  " set the Liter/Pulse	Liter/Pulse Max: 0.00000 Min: 0.00055 0.01000
6	Press "  " quit setup menu , LCD show confirm menu	Liter/Pulse 4000.0 ←ENT ESC → 5000.0
7	Press "  " to confirm the change , Press "  " to give up modify	Freq Direct Freq Max(Hz) → Liter/Pulse ↓ PulseWidth(ms)
8	Press "  " three times back to measurement , also you can continue other operation	

11 .) Cumulate Clear

Steps	Operation instructions	Interface show
1	In the measurement mode, press “  ” into configuration menu,Click “  ” to choice “System” item	
2	press the key of  ,show password interface,enter password,press the key of  enter into system constituent menu	
3	Press “  ” to choice “Total Set” item	
4	Press “  ” into “Clear Total” menu	
5	Press “  ” into “ Clear Total” menu,Prees“  ” or “  ” set the YES or NO	
6	Press “  ”quit setup menu , LCD show confirm menu	
7	Press“  ” two times to Clear Total, Press“  ”to give up modify	
8	Press“  ”three times back to mesurement,also you can continue other operati on	

12.)Preset total positive

Steps	Operation instructions	Interface show
1	In the measurement mode, press "  " into configuration menu, Click "  " to choice "System" item	
2	press the key of  ,show password interface,enter password,press the key of  enter into system constituent menu	
3	Press "  " to choice "Total Set" item	
4	Press "  " into " Pulse Output" menu	
5	Press "  " to choice "FWD Preset(m3)" item	
6	Press "  " into " Clear Total" menu, Press "  " or "  " set the YES or NO	
8	Press "  "quit setup menu	
7	Press "  "three times back to measurement, also you can continue other operation	



Technical Support:

Tel:1800-7574 Fax: 070 7574 7574

Email: js@highper.co.kr